



MANUFACTURED TO AS3947.4.1 - 1995

TAPS @ 50% 65% 80% 100%

OPTIONS - TEMPERATURE SWITCHES
THERMISTORS

CODE	MAX. AMPS FOR 15 SEC.	MOTOR K.W.			DIMENSIONS										MASS KG
		STARTS PER HOUR	3	12	30	A	B	C	D	E	F ^①	G			
B	160	11	7.5	4	220	123	176 ^②	160	93	25	25	*	14		
D	320	22	15	7.5	290	138	225 ^②	160	108	25	*	27			
F	660	45	30	15	320	138	245 ^②	160	108	25	*	33			
H	950	90	55	30	350	167	286	300	127	20	6	45			
J	1350	132	90	45	390	167	306	300	127	30	6	54			
L	1900	185	132	55	420	177	325	300	127	30	8	72			
N	2500	250	185	90	465	177	355	300	127	50	8	88			
P	3000	315	220	110	560	254	420	300	194	10	10	165			
R	4000	400	280	150	620	254	460	300	194	40	10	223			
T	6000	500	400	220	630	280	500	540	220	10	13	293			
V	7500	750	500	280	690	280	540	540	220	30	13	351			
X	10000	1000	750	400	750	280	580	540	220	50	13	408			

* TUNNEL TERMINALS TO SUIT 16mm CABLE

① TERMINALS ARE ON THE WINDING & THIS DIMENTION MAY VARY.

② LIFTING EYES NOT FITTED

TERMINALS ARE TUNNEL TYPE ON TOP OF TRANSFORMER

<p>COAST ELECTRICAL INDUSTRIES A. C. N. 001 936 456 CORNER KENNY & WEST STREETS WOLLONGONG 2500 AUSTRALIA</p>				<p>PTV. LTD. MOTOR STARTING AUTO TRANSFORMERS 415V 3 PHASE</p>			
REVISION #3	REVISION #2	DRAWN RF	DATE 9/4/96	DRAWING #	REV.		
F.H.J CORRECTION	DIMENSIONS	CHK.	SCALE N.T.S.	586	3		